

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE	PAGE 1 OF 3 PAGES
2. AMENDMENT/MODIFICATION NO. AMENDMENT NO. 0002		3. EFFECTIVE DATE 05/25/10	4. REQUISITION/PURCHASE REQ. NO.	5. PROJECT NO. (If applicable) 10-0207	
6. ISSUED BY CODE		CODE mks	7. ADMINISTERED BY (If other than Item 6) CODE		See Item 6
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) Officer in Charge of Construction MCI-East 1005 Michael Road Camp Lejeune, NC 28547-2521			(X)	9A. AMENDMENT OF SOLICITATION NO. N40085-10-R-0207	
CODE			FACILITY CODE	9B. DATED (SEE ITEM 11) 05/12/10	
				10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 11)	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.
 Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:
 (a) By completing items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted;
 or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (If required)

**13. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

10-0207, P-725, Upgrade Fuel Pump Station MCAS New River

(CONTINUED)

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR		16B. UNITED STATES OF AMERICA	
15C. DATE SIGNED		16C. DATE SIGNED	
(Signature of person authorized to sign)		(Signature of Contracting Officer)	

CONTINUATION SHEET

1. Question: This project scope does not include installing any new metering, level indicators, or other necessary equipment to provide inventory calculations as requested above. This requirement does not seem needed for this project. Please clarify intent.

1. Answer: This "Paragraph 3.8 SYSTEM COMMISSIONING AND ACCEPTANCE TEST" is a verification of the flows indicated by the equipment installed. The verification is for the commissioning only and not intended to be a permanent installation. There are several ways to verify the flow. The Contractor can choose the best and submit his certified documents after the test.

2. Question: According to SECTION 33 52 43.00 20 WELDING FOR CARBON STEEL PIPING 2.5.1 Radiographic X-ray is required. What about Ultra-Sound testing in lieu of Radiography?

2. Answer: Follow the requirements listed in the specifications; use Radiographic X-ray.

3. Please reference drawing G-004 of Amendment 001-

Note # 2 "Project Scope" states a separate contractor will be working at this site to remove and replace contaminated soils at this site;

Notes #1 and 2 - "Contaminated Soils" states to assume all soils contacted are contaminated and a separate contractor shall be responsible for the contaminated soils.

Question: When these notes are both applied to the project, it appears the "separate contractor" will be responsible for all excavations and fill associated with this project. Is this the intention of the Govt. for this project?

3. Answer: Response to: Note # 2 "Project Scope" states a separate contractor will be working at this site to remove and replace contaminated soils at this site.

There are two areas of contaminated soil to be excavated, one for this project and one for another project which is about 30 meters away. The other soil remediation project may occur at the same time as this project so coordination between the two excavation areas will be necessary.

CONTINUATION SHEET

Response to: Notes #1 and 2 - "Contaminated Soils" states to assume all soils contacted are contaminated and a separate contractor shall be responsible for the contaminated soils.

For the soil remediation of this project, all of the contaminated soil shall be removed and disposed by a qualified contractor or subcontractor and performed as listed in the "Scope of Work MILCON Soil Excavation"

4. Reference: Amendment No. 0001 - Scope of Work - Milcon Soil Excavation Paragraph D.1 "The contractor will excavate an area approximately 53 feet wide by 82 feet long to a depth of seven feet below the existing water table."

Question: What is the existing water table depth for this site?

4. Answer: The water table depth at this site varies from 5 to 7 feet.